

# Georgetown City Fire Department

## Group Daycare Home Inspection Checklist

Daycare Name: \_\_\_\_\_

Inspector: \_\_\_\_\_

Address: \_\_\_\_\_

Date of Inspection \_\_\_\_\_

Pass	Fail	N/A		Pass	Fail	N/A	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	City Business License posted	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	License has not expired.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Must meet requirements for residential occupancies				
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	GDCH separated from other occupancies 1 hour construction				
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Facilities in Group R2 occupancies are located on the floor of exit discharge				
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Facility has two independent means of escape				
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Facility is on the floor of exit discharge for clients in first grade or younger				
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Door between floor of exit discharge and lower floor(s) equipped with self closing 1 3/4 solid core door rated				
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Address numbers properly posted				
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	GDCH is not in a manufactured home.				
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Interior finish of GDCH and exits are a minimum of Class C				
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Fire escape plan developed, posted, and made available to employees and local fire department				
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Fire escape plan notes the location of all crib infants				
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Fire drills conducted per Educational requirements of SFPC (monthly)				
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Written records of fire drills are kept for 3 years				
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Smoke Detector installed in each room used for Daycare				
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Smoke Detectors are installed and maintained properly (NFPA 72)				
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2A10BC Fire extinguisher installed in proper location in kitchen				
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Fire extinguisher properly mounted on the wall				
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Fire Extinguisher serviced annually				
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Fire Extinguisher checked monthly				
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Special protective covers installed on all electrical receptacles in the facility				
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Heating devices listed				
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Portable electric heaters prohibited except in emergencies and are guarded				
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Unguarded open flame heaters prohibited				
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Unvented gas heaters have Oxygen Depletion Device and Automatic Gas Pilot shutoff device installed				
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Fireplaces have screens, partitions to protect children from burns				
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	No more than 3 infants or meets infant care requirement; no more than 12 children				
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Vented Gas fire places prohibited in bathrooms or bedrooms unless it meets volume requirements 8.3.2				

Next Inspection \_\_\_\_\_

Occupant Signature: \_\_\_\_\_